

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1599:103

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Ziton (Pty) Ltd., PO Box 4965, Capetown, South Africa 8000
Contact: Roger Airey 01127215066045 FAX 01127215066060

DESIGN: Model Z6U-BS1 detector base. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as detector bases for use with listee's separately listed compatible fire alarm control units and Models Z610AU-2, Z610U-2, Z630AU-2, Z630OU-2 smoke detector heads (CSFM Listing Nos. 7271-1599:106 and 7272-1599:104) and Models Z620U-621-2, Z620U-622-2 heat detector heads (CSFM Listing No. 7270-1599:105). Refer to listee's Installation Instruction Manual for details.

08-05-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 5, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**